


KING CAREER EDUCATION CENTER



CAREER TRAINING SITE

TR. 2

CAREER CENTER DR
30 ft UTIL ESMT

TR. 4

GOOSE EXCH
LAND
TR. X2

MALLARD LANE

EDGE OF ASPHALT

230FT
2PL

15-41529

2PL

24 ft ELEC ESMT

TIE INTO
2PL MAIN

EASEMENT REQUIRED

CLEARING 100FT

20 ft CREEK ESMT

152

5/8PL79

6

23

15

15

26

15

16

U. A. A. SUBDIVISION

TR. 1A

END MAIN AT
FAR SIDE OF
STRUCTURE

SAND
STORAGE
BUILDING

SEAWOLF DRIVE

25 ft SAN. SEWER & GAS ESMT

LOC BOX

5'

10 ft T&E ESMT.

5 ft SEWER ESMT.

ENSTAR NATURAL GAS COMPANY




ANCHORAGE, ALASKA

PROPOSED GAS MAINS

UAA SAND STORAGE BUILDING

SHEET / OF /

SCALE 1"=60'



ER #:

PROP #: 8648

GRID(S): A1634

DESIGN SPECIFICATIONS:

- A. PIPE DIAMETER: 2"
- B. WALL THICKNESS OR SDR: SDR11
- C. MATERIAL GRADE: PE 3408/4710
- D. COATING TYPE: N/A
- E. MAOP: 60 PSIG

REVISION

ORIGINAL

BY DATE CHKD

JA 2-7-24 GC

JA 5-19-23 MS